



U. S. Department of Homeland Security
United States Coast Guard
Certificate of Approval

Coast Guard Approval Number: 164.106/16/0

Expires: 30 January 2013

PRIMARY DECK COVERINGS (IMO)

CROSSFIELD PRODUCTS, INC.
140 Valley Road
Roselle Park NJ 07204

Type "Dex-O-Tex Quik-Set Underlayment" cement primary deck covering approved in maximum thickness of 1/4 inch (6.4 mm) and nominal weight of 2.3 pounds/square foot (11.6 kg/square meter).

Tested to Part 6 of Annex 1 of the IMO FTP Code (low flammability). Meets paragraph 2.2 of Annex 2 (low smoke and toxicity) of the IMO FTP Code.

Identifying Data: Southwest Research Institute (SwRI) report Project No. 01.04917.01.162 dated August 2002, SwRI follow-up procedure document Project No. 01.02500.100 dated December 2002, and USCG letter dated 28 February 2003.

Follow-up Program: SwRI

Approval valid only for products from above factory location.

Supersedes and extends Appr. No. 164.106/16/0 dated 23 September 2005.



1408/08


The manufacturer is allowed to affix the Mark of Conformity according to Article 11 in the Council Directive 96/98/EC on Marine Equipment and issue a Declaration of Conformity as allowed by the "Agreement between the European Community and the United States of America on Mutual Recognition of Certificates of Conformity for Marine Equipment" signed February 2004. Item complies with requirements of Annex A.1, Item No. A.1/3.1 of the directive.

*** END ***

THIS IS TO CERTIFY THAT the above named manufacturer has submitted to the undersigned satisfactory evidence that the item specified herein complies with the applicable laws and regulations as outlined on the reverse side of this Certificate, and approval is hereby given. This approval shall be in effect until the expiration date hereon unless sooner canceled or suspended by proper authority.



GIVEN UNDER MY HAND THIS 30th DAY OF
JANUARY 2008, AT WASHINGTON D.C.


K. J. HEINZ
Chief, Lifesaving and Fire Safety Division
BY DIRECTION OF THE COMMANDANT